Site 12, Box 50, RR#1
Didsbury, AB
T0M 0W0

Phone: 403-335-4304
Cell: 404-559-6729
E-mail:
jejohnson@chinooksedge.ab.ca

WASTEWATER TREATMENT SYSTEM MAINTENANCE RECORD

NEXT SERVICE	SCHEDULED ACTIVITY	PUMPING CO. PHONE	ACTIVITIES COMPLETED	COMMENTS
Jan. 2007	Inspection and maintenance	Joe Pumper 555-1234	Inspection	Pump screen cleaned. Sludge layer okay. May need pumping next year.

Note: For the first three years of operation your system should be inspected annually.